

## ICC-ES PMG Listing

## PMG-1023

Revised: October 1, 2009

*This listing is subject to re-examination in one year.*[www.icc-es.org/pmg](http://www.icc-es.org/pmg) | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

CSI: DIVISION: 15—MECHANICAL  
Section: 15810—Ducts

Product: AK Duct™ and AK Duct™ Premier

Listee: CDC Enterprises, Inc.  
13355 George Weber Drive, Suite M  
Rogers, Minnesota 55374  
[www.cdcenterprisesinc.com](http://www.cdcenterprisesinc.com)

Compliance with the following codes:

2009 *International Residential Code*® (IRC)  
2009 *International Mechanical Code*® (IMC)  
2009 *Uniform Mechanical Code*® (UMC)\*\* *Uniform Mechanical Code* is a copyrighted publication of the International Association of Plumbing and Mechanical Officials,

Compliance with the following standards:

ASTM D 2412 Standard Test Method for Determination of External Loading Characteristics of Plastic  
Pipe by Parallel-Plate Loading  
LC1014 Listing Criteria for Underground Plastic Air Ducts  
UL 723 Test for Surface Burning Characteristics of Building Materials

Identification:

The CDC Enterprises AK Duct™ and AK Duct™ Premier duct and fittings described in this listing are identified by a stamp bearing the manufacturer's name (CDC Enterprises, Inc.) and/or trademark, the product name and the model number. The ICC-ES PMG listing number (PMG-1023) and/or the ICC-ES PMG listing mark must be placed on the listed product's packaging or installation instructions.

Installation:

Installation of AK Duct™ and AK Duct™ Premier duct and fittings must comply with the manufacturer's published installation instructions and the applicable codes.

**Residential Sealing Method:** Two sections of pipe (or pipe and fitting) are placed end to end. The adhesive backing is peeled off a gasket and the gasket is wrapped around the duct. The gasket should overlap approximately 1/4 inch (6 mm). A clamp is placed around the gasket, with the clamp and gasket lined up. The clamp screw is tightened with a drill. Clamp ends do not have to meet each other to be airtight.

**Commercial Sealing Method:** A bead of sealant is applied to each flanged end and around the bolt holes. Two sections of pipe (or pipe and fitting) are placed end to end. The bolts, nuts and washer are

installed through the predrilled template holes. Bolts are tightened until they are flush. Sealant is used to cover both ends of each nut and bolt.

Underground Systems: The CDC Enterprises AK Duct™ duct and fittings are laid directly upon a sub-bed of gravel or other suitable coarse fill. Any unfilled gaps below the pipe must be filled and compacted with pea gravel or aggregate so as to create a level sub-bed. A vapor barrier is not required between the pipe and soil. Back-fill material must be spread evenly around the pipe and gently tamped into place.

The loading of the duct from wet concrete and/or soil above the duct must be limited so as not to produce deflections greater than 15 percent of the original duct diameter (see Table 1).

Surface Burning Characteristics: AK Duct™ Premier has a flame spread index of 200 or less when tested in accordance with UL723 (ASTM E 84).

**Models:** The CDC Enterprises AK Duct™ duct and fittings are an underground air duct and fitting system for use in forced-air heating and cooling systems in accordance with Section 603.8 of the IMC, Section M1601.1.2 of the IRC or Section 105.0 of the UMC, as applicable. See Table 2, below.

The CDC Enterprises AK Duct™ Premier duct and fittings are an above ground air duct and fitting system for use in forced-air heating and cooling systems in accordance with IRC Section M1601.1.1. See Table 2, below.

**Conditions of Listing:**

1. Designs using AK Duct™ duct and fittings must be limited to systems with a maximum air temperature of 150°F (66°C) at the discharge of the unit entering the duct system. Sizing must be in accordance with Section 603.2 of the IMC, Section M1601.1 of the IRC or Section 601.2 of the UMC.
2. AK Duct™ duct and fittings can be installed underground or embedded within concrete slabs.
3. AK Duct™ Premier duct and fittings can be installed as part of an aboveground duct system in accordance with IRC Section M1601.1.1.
4. AK Duct™ duct and fittings must slope to allow drainage to a point provided with access.
5. The design of concrete slabs with an embedded air duct is beyond the scope of this evaluation.
6. Underground air duct pipes located below the design flood elevation must be designed and installed to resist hydrostatic and hydrodynamic loads and stresses, including the effects of buoyancy, during the occurrence of flooding to the design flood elevation, in accordance with Section 603.13 of the IMC, Section M1601.3.8 of the IRC or Section 604.6 of the UMC, as applicable.
7. The maximum depth below BFE in which the duct can be installed based on testing per LC1014 Section 4.3.2 is 27 inches (686 mm).

**TABLE 1—LOADING<sup>1</sup>**

PIPE DIAMETER (inches)	AVERAGE WALL THICKNESS AS TESTED (inch)	LOAD at 15% DEFLECTION (lbs/lineal ft)
6	0.429	205
8	0.507	353
10	0.416	102
12	0.575	117
14	0.700	135
16	0.472	189
18	0.692	208
20	0.460	433
24	0.770	390

For **SI:** 1 inch = 25.4 mm, 1 lb = 14.59 N/m.

<sup>1</sup> Loads are the results of ASTM 2412 testing without safety factors yielding a 15% deflection based on inside diameter.

TABLE 2—SYSTEM COMPONENTS

ITEM	DESCRIPTION	SIZE (inches)
ACCESSORIES:20-0027	Foam Trench Block	
ACCESSORIES:20-0030	Damper	
ACCESSORIES:20-0050	Boot Extension	4"x 12" - 16"
ACCESSORIES:20-0100A	Air Test Kit	13"
ACCESSORIES:20-0101A	Air Test Kit	8"
ACCESSORIES:20-0200	Boot Reducer	4"x 12" to 2 1/4"x 12"
ACCESSORIES:20-0300	Bolt with 1 nut & 2 washers (pkg of 12)	2-1/2" x 1/4"
ACCESSORIES:20-0711	Airtite Sealant	
BLUE:03-0090	Rubber Gasket for 3" HV	
BLUE:03-2510	Pipe	3"
BLUE:03-2511	End Cap	3"
BLUE:03-2530	90 Degree Elbow (Long Sweep)	3"
BLUE:03-2531	90 Degree Elbow (Short Sweep)	3"
BLUE:03-2532	45 Degree Elbow	3"
BLUE:03-2533	22.5 Degree Elbow	3"
BLUE:03-2534	Sound Attenuator	3"
BLUE:03-2535	Sound Attenuator Replacement Cartridge	3"
BLUE:03-2590	Saddle Take Off	3"
BLUE:06-2501	Offset Footer Boot	6"
BLUE:06-2502	90 Degree Boot (4 x 12)	6"
BLUE:06-2510	Pipe	6"x 8'
BLUE:06-2511	End Cap	6"
BLUE:06-2530	90/45 degree Elbow	6"
BLUE:06-2560	Plenum Adapter with Screws	6"
BLUE:06-2570	Center Saddle - 4" x 12" Boot with screws	6"
BLUE:08-2502	90 Degree Boot (4 x 12)	8"
BLUE:08-2510	Pipe	8"x 8'
BLUE:08-2511	End Cap	8"
BLUE:08-2520	Tee	8"
BLUE:08-2525	Tee Reducer	8"x 8"x 8"-6"
BLUE:08-2530	90/45 Elbow	8"
BLUE:08-2540	Reducer	8"x 6"
BLUE:08-2560	Plenum Adapter with Screws	8"
BLUE:08-2565	Plenum Adapter with 12" piece & End Cap	8"
BLUE:08-2570	Center Saddle - 4"x12" Boot with screws	8"
BLUE:10-2510	Pipe	10"x 8'
BLUE:10-2511	End Cap	10"
BLUE:10-2515	Inline Boot (4 x 12)	10"
BLUE:10-2520	Tee	10"
BLUE:10-2530	90/45 degree Elbow	10"
BLUE:10-2540	Round Reducer	10"x 8"
BLUE:10-2545	Round Reducer	10"x 8"x 6"
BLUE:10-2550	Offset Saddle - 4" x 12" Boot with screws. Fits 10" pipe	10"
BLUE:10-2560	Plenum Adapter with Screws	10"
BLUE:10-2570	Center Saddle - 4 x 12 boot with screws	10"
BLUE:10-2578	Saddle Reducer (with screws) Fits 10" & 12" Pipe	10"- 8"x 6"
BLUE:12-2510	Pipe	12"x 8'
BLUE:12-2511	End Cap	12"
BLUE:12-2520	Tee	12"
BLUE:12-2530	90/45 Degree Elbow	12"
BLUE:12-2540	Reducer	12"x 10"

ITEM	DESCRIPTION	SIZE (inches)
BLUE:12-2547	Reducer	12"x 10"x 8"x 6"
BLUE:12-2550	Offset Saddle - 4 x 12 boot with screws. Fits 12", 14", 16" & 18" Pipe	12"
BLUE:12-2551	Offset Saddle - 4" x 24" Boot with screws	12"
BLUE:12-2560	Plenum Adapter with Screws	12"
BLUE:12-2577	Saddle Reducer	12"x 10"
BLUE:14-2510	Pipe	14"x 8"
BLUE:14-2511	End Cap	14"
BLUE:14-2530	90/45 Degree Elbow	14"
BLUE:14-2560	Plenum Adapter with Screws	14"
BLUE:14-2575	Wye	14"
BLUE:14-2577	Saddle Reducer - Fits 14", 16", & 18" Pipe	14"x 12"
BLUE:16-2510	Pipe	16"x 8"
BLUE:16-2511	End Cap	16"
BLUE:16-2530	90/45 Degree Elbow	16"
BLUE:16-2540	Reducer	16"x 14"
BLUE:16-2547	Reducer	16"x 14"x 12"x 10"
BLUE:16-2560	Plenum Adapter with Screws	16"
BLUE:16-2575	Wye	16"
BLUE:16-2577	Saddle Reducer - Round - Fits 16" & 18" Pipe	16"x 14"
BLUE:16-3510F	Pipe with Flange	16"x 8"
BLUE:18-2510	Pipe	18"x 8"
BLUE:18-2511	End Cap	18"
BLUE:18-2530	90/45 Degree Elbow	18"
BLUE:18-2540	Eccentric Reducer	18"x 16" x 14"x 12"
BLUE:18-2560	Plenum Adapter with Screws	18"
BLUE:18-2577	Saddle Reducer - Round	18"x 16"
BLUE:18-3510F	Pipe with Flange	18"x 8"
BLUE:18-3541F	Eccentric Reducer with Flange	18"x 16"
BLUE:20-0010	Plenum	20"x 24"x 36"
BLUE:20-0015	Plenum	25"x 30"x 48"
BLUE:20-0050	Boot Extension	4x12 - 16"
BLUE:20-0060	Universal Linear Diffuser Adapter	
BLUE:20-0061	Linear Diffuser 49" x 7" x 8" O.D.	48"
BLUE:20-0062	Linear Diffuser 37" x 7" x 8" O.D.	36"
BLUE:20-0063	Linear Diffuser 25" x 7" x 8" O.D.	24"
BLUE:20-3510F	Pipe with Flange	20"x 8"
BLUE:20-3530F	90/45 Degree Elbow with Flange	20"
BLUE:20-3541F	Eccentric Reducer with Flange	20"x 18"
BLUE:20-3542F	Eccentric Reducer	20"x 18"x 16"
BLUE:20-3575F	Tee/Wye	20"
BLUE: 24-3510F	Pipe with Flange	24" x 8"
BLUE: 24-3530F	90/45 Degree Elbow with Flange	24"
BLUE: 24-3541F	Eccentric Reducer with Flange	24" x 20"
BLUE: 24-3575F	Tee/Wye	24"
BLUE:24-3542F	Eccentric Reducer with Flange	24"x 20"x 18"
BLUE:24-3543F	Eccentric Reducer with Flange	24"x 20"x 18"x 16"
CLAMPS:03-0080	Stainless Steel Clamp	3"
CLAMPS:06-0080	Clamps & Gasket Set	6"
CLAMPS:08-0080	Clamps & Gasket Set	8"
CLAMPS:10-0080	Clamps & Gasket Set	10"
CLAMPS:12-0081	Clamps & Gasket Set	12"
CLAMPS:14-0081	Clamps & Gasket Set	14"

ITEM	DESCRIPTION	SIZE (inches)
CLAMPS:16-0081	Clamps & Gasket Set	16"
CLAMPS:16-0100	Steel Clamp	16"
CLAMPS:16-0912	wide W6403 Gasket	12"
CLAMPS:18-0081	Clamps & Gasket Set	18"
CLAMPS:18-0100	SS Clamp	18"
CLAMPS:18-0912	wide W6403 Gasket	12"
CLAMPS: 20-0081	Clamps & Gasket Set	20"
CLAMPS: 24-0081	Clamps & Gasket Set	24"