



Listing Number: PMG-1031
Effective Date: August 1, 2008
This listing is subject to re-examination in one year.

ICC Evaluation Service, Inc. www.icc-es.org/pmg	Business/Regional Office 5360 Workman Mill Road, Whittier, California 90601 562.699.0543 Regional Office 900 Montclair Road, Suite A, Birmingham, Alabama 35213 205.599.9800 Regional Office 4051 West Flossmoor Road, Country Club Hills, Illinois 60478 708.799.2305
--	---

CSI: DIVISION: 15—MECHANICAL
Section: 15050—Basic Mechanical Materials and Methods

Product: Air Conditioner (A/C) Plastic Auxiliary Condensate Drain Pan

Listee: DiversiTech Corporation
6650 Sugarloaf Parkway
Duluth, Georgia 30097
www.diversitech.com

Compliance with the following codes:

2006 *International Mechanical Code*® (IMC)
2006 *International Residential Code*® (IRC)
2006 IAPMO *Uniform Mechanical Code* (IAPMO UMC)*
1997 *Standard Mechanical Code*® (SMC)
1998 *International One-and Two-Family Dwelling Code*® (IOTFDC)

* *Uniform Mechanical Code* is a copyrighted publication of the International Association of Plumbing and Mechanical Officials, 5001 East Philadelphia Street, Ontario, California 91761.

Compliance with the following standards:

Prescriptive requirements of the codes

Identification:

The DiversiTech plastic auxiliary condensate drain pans must bear the manufacturer's name (DiversiTech Corporation) and/or trademark, the date of manufacture and either the evaluation report number (ESR-1484) or the ICC-ES PMG listing number (PMG-1031) and/or the ICC-ES PMG listing mark.

Installation:

Installation of the plastic auxiliary condensate drain pans must comply with the applicable code and the manufacturer's published installation instructions. The manufacturer's published installation instructions must be strictly adhered to and a copy of the instructions must be available at the jobsite at all times during installation.

The auxiliary drain pan size selected must be at least 3 inches (76.2 mm) larger, in width and length, than the coil dimensions of the air-conditioning unit.

The auxiliary drain pan must drain to a conspicuous point of disposal to alert occupants in the event of a stoppage of the primary drain in accordance with the applicable code.



Listings are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the listing or a recommendation for its use. There is no warranty by ICC Evaluation Service, Inc., express or implied, as to any finding or other matter in this listing, or as to any product covered by the listing.

Copyright © 2008

Models: DiversiTech Corporation's A/C Plastic Auxiliary Condensate Drain Pan is vacuum-formed from general-purpose acrylonitrile butadiene styrene (ABS) plastic. All DiversiTech auxiliary drain pans will contain a depth of 2 inches (50.8 mm) of water, and are equipped with a $\frac{3}{4}$ -inch-diameter (19.0 mm) polyvinyl chloride (PVC) discharge fitting.

The drain pans range in width from 12 inches to 36 inches (304.8 mm to 914.4 mm) and in length from 24 inches to 60 inches (609.6 mm to 1524.0 mm). All drain pans described in this listing are formed from minimum 0.065-inch-thick (1.65 mm) ABS sheet.