



Listing Number: PMG-1033
Effective Date: August 1, 2008
This listing is subject to re-examination in one year.

ICC Evaluation Service, Inc.
www.icc-es.org/pmg

Business/Regional Office 5360 Workman Mill Road, Whittier, California 90601 | 562.699.0543
Regional Office 900 Montclair Road, Suite A, Birmingham, Alabama 35213 | 205.599.9800
Regional Office 4051 West Flossmoor Road, Country Club Hills, Illinois 60478 | 708.799.2305

CSI: DIVISION: 15—MECHANICAL
Section: 15140—Domestic Water Piping
Section: 15180—Heating and Cooling Piping
Section: 15411—Fittings, Trim and Accessories

Products: Speedfit® Tubing and Fittings

Listee: John Guest Ltd.
Horton Road
West Dayton, Middlesex UB78JL
United Kingdom
www.johnguest.co.uk

Compliance with the following codes:

2006 *International Plumbing Code*® (IPC)
2006 *International Mechanical Code*® (IMC)
2006 *International Residential Code*® (IRC)
2006 IAPMO *Uniform Plumbing Code** (IAPMO UPC)
2006 IAPMO *Uniform Mechanical Code** (IAPMO UMC)

* *Uniform Plumbing Code* and *Uniform Mechanical Code* are copyrighted publications of the International Association of Plumbing and Mechanical Officials, 5001 East Philadelphia Street, Ontario, California 91761.

Compliance with the following standards:

ASSE 1061
ASTM F 876
ASTM F 877
ICC-ES AC122
ICC-ES AC311
NSF 14
NSF 61

Identification:

Speedfit® Tubing is marked every 3 feet (914 mm) with the following:

- The John Guest logo (see Figure 1)
- The name “Speedfit®”
- Nominal tube size
- Material designation (PEX)
- Potable water designation (PW)
- Standard dimension ratio (SDR9)
- Temperature and pressure ratings
- ASTM F 876/F 877 designation



Listings are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the listing or a recommendation for its use. There is no warranty by ICC Evaluation Service, Inc., express or implied, as to any finding or other matter in this listing, or as to any product covered by the listing.

- ASSE 1061 fitting mark
- Production code
- The name of the inspection agency [NSF International (AA-633)]
- The ICC-ES evaluation report number (ESR-1931) or the ICC-ES PMG listing number (PMG-1033) or the ICC-ES PMG listing mark.

Speedfit® Fittings are marked with the following:

- The John Guest logo (see Figure 1)
- Nominal diameter
- Potable water marking (PW)
- Letter designation of fitting manufacturer
- The designations ASTM F 877 and ASSE 1061

Packaging for the fittings is marked with the ICC-ES evaluation report number (ESR-1931) or the ICC-ES PMG listing number (PMG-1033) or the ICC-ES PMG listing mark.

Installation:

Speedfit® tubing and push-fit fittings must be installed in accordance with the applicable code and the manufacturer's published installation instructions. The pipe or tubing is cut to length, and for PEX an insert is fitted into the cut end of the tube. The pipe or tubing is pushed into the fitting up to the stop. The fitting has a cursor line on the outer surface to show the full insertion depth for the tubing.

Models: Speedfit® Tubing is a cross-linked polyethylene (PEX) tubing used in radiant heating systems and potable hot- and cold-water distribution systems.

Speedfit® tubing is manufactured from red, white or blue cross-linked PEX.

The tube is available in nominal diameters of $\frac{1}{2}$, $\frac{3}{4}$ and 1 inch (12.7, 19.1 and 25.4 mm), and in coils 100 feet (30.4m) long, or in straight lengths 10 feet (3.04m) long.

Speedfit® Fittings are push-fit fittings designed for use with Speedfit® tubing, copper tube, chlorinated polyvinyl chloride (CPVC) or PEX in accordance with this listing.

Speedfit® fittings are also manufactured from white cross-linked PEX; however, some of the adaptors are brass. See Table 1 for recognized fittings.

The Speedfit® Tubing and Fitting System satisfies the requirements of ASTM F 876, ASTM F 877 and NSF 14. All components in contact with potable water satisfy NSF 61. Speedfit® tube and fitting products are pressure-rated for 100 psi (689 kPa) at 180°F (82°C), and 160 psi (1100kPa) at 73°F (23°C), for a standard dimension ratio of 9. Standard dimension ratio is the ratio of outside diameter to wall thickness and is constant for all tube sizes over $\frac{1}{2}$ inch (12.7 mm).

Speedfit® push-fit fittings are recognized for use with Speedfit® PEX tubing, using insert sleeves, in accordance with ASSE 1061, ICC-ES LC-1009/AC311 and ASTM F 877 as well as NSF 61. Speedfit® fittings have a collet with stainless steel gripping teeth and a rubber O-ring seal.

Insert fittings are required and are provided in two types:
The standard insert sleeve does not have any O-ring seals.
The Superseal Insert Sleeve has two O-ring seals.

Speedfit® push-fit fittings are recognized as having satisfied ASSE 1061 for use with copper tubing, chlorinated polyvinyl chloride (CPVC), and PEX tubing (provided the PEX tubing is marked in accordance with the Identification section of this listing).

Conditions of Listing:

1. Horizontally laid pipe must be secured in such a manner that temperature-induced expansion and contraction are accommodated. Mounting brackets and installation hardware are provided by the manufacturer.
2. Details of the design and installation of the radiant heating system must be submitted to the code official for approval. All circuits must be formed from continuous lengths of tubing, from manifold supply to return. No splices are allowed. The system may be installed in either concrete or wood floors. When the system is embedded in concrete floors, a moisture barrier must be laid over a concrete-base slab that has a minimum thickness of $3\frac{1}{2}$ inches (38 mm). Under-floor insulation and reinforcing mesh must be placed on the slab. The tubing is uncoiled and attached to the mesh using soft steel wire or clips. A concrete topping is laid over the tubing. When embedment is in concrete, the installation, including minimum concrete cover, must comply with IBC Section 1906.3 or IRC Section R506. When the tubing is installed over polystyrene boards, the boards must comply with IBC Section 2603 or IRC Section R314.
3. The tubing must be pressure tested for leaks before installation of covering. The leak test must be witnessed by the code official or the code official's designated representative.
4. When installation is in fire-resistance-rated assemblies, evidence of compliance with IBC Section 712 (penetrations) must be provided to the code official for approval.
5. Speedfit[®] tubing and fittings must be protected from exposure to direct sunlight. Tubing and fittings must be protected from physical damage with an oversized flexible corrugated sleeve at structural mass penetrations and when the tube is uncovered. Annular spaces between sleeves and pipes must be filled or tightly caulked in an approved manner.
6. All systems must be installed in accordance with the manufacturer's installation instructions, which are provided with the product. Installation must conform to relevant requirements of the referenced codes and is subject to approval by the code official. Manufacturer's instructions must be furnished to the code official upon request.
7. During placement of the cover over the tubing, the tube must be maintained at the greater of $1\frac{1}{2}$ times the working pressure or 100 psi (689.4 kPa), whichever is greater.
8. Clearances from heat-producing equipment must be in accordance with the applicable code.
9. Minimum bending radius of the tube must be six times the outside tube diameter for cold-bent tube. The outside diameter is nominal diameter plus $\frac{1}{8}$ inch (3.2 mm).
10. Speedfit[®] push-fit fittings:
 - a. Speedfit[®] push-fit fittings are limited to use in interior, above-grade installations with operating pressures of 80 psi (551.2 kPa) or less, and where the fittings are not embedded in concrete.
 - b. Pipe or tubing joined by Speedfit[®] push-fit fittings must not be used to support loads beyond those of the water-filled pipe and fittings.
11. Materials used with push-fit fittings:
 - a. Copper tubing must conform to ASTM B 88.
 - b. CPVC tubing must conform to ASTM D 2846.
 - c. PEX tubing: Use of push-fit fittings is limited to PEX tubing listed as complying with ASTM F 876 and ASTM F 877 and labeled to indicate use with fittings complying with ASSE 1061.

TABLE 1— FITTING DESCRIPTIONS

PEX		PEX	
PEI0220	1/2" CTS UNION TEE - WHITE	PEI3028B	3/4" x 1/2" x 1/2" CTS REDUCING TEE
PEI0228	3/4" CTS UNION TEE- WHITE	PEI3028C	1/2" x 1/2" x 3/4" CTS REDUCING TEE
PEI0236	1" CTS UNION TEE-WHITE	PEI3028D	3/4" x 1/2" x 3/4" CTS REDUCING TEE
PEI0320	1/2" CTS UNION ELBOW	PEI4620	1/2" CTS END CAPS
PEI0328	3/4" CTS UNION ELBOW - WHITE	PEI4628	3/4" CTS END CAPS
PEI0336	1" CTS UNION ELBOW - WHITE	PEI4636	1" CTS END CAPS
PEI0420	1/2" CTS UNION CONNECTOR - WHITE	PEI532020	1/2" CTS x 1/2" STEM x 1/2" CTS TEE
PEI0428	3/4" CTS UNION CONNECTOR - WHITE	PEI532820	1/2" CTS x 1/2" STEM x 1/2" CTS TEE
PEI0436	1" CTS UNION CONNECTOR - WHITE	PEI532828	3/4" CTS x 3/4" STEM x 3/4" CTS TEE
PEI062820	3/4" CTS TO 1/2" CTS REDUCER	PEIBTC2034	1/2" CTS x 1/2" NPSM FEMALE STRAIGHT CONNECTOR
PEI063628	1" CTS - 3/4" CTS REDUCER	PEIBTC20C75	1/2" CTS x 1/8" BALLCOCK ELBOW CONNECTOR - 15/16 UNS
PEI202820	3/4" CTS - 1/2" CTS REDUCING UNION	PEISTC2034	1/2" CTS x 1/2" NPSM FEMALE STRAIGHT CONNECTOR
PEI222020	1/2" CTS STEM ELBOW CONNECTOR	PEISTC20C75	1/2" x 1/8" FEMALE BALLCOCK CONNECTOR - 15/16 UNS
PEI222828	3/4" CTS STEM ELBOW CONNECTOR		
PEI3028A	3/4" x 3/4" x 1/2" CTS REDUCING TEE		
BRASS		BRASS	
MWI012024	1/2" CTS X 1/2" NPT STRAIGHT ADAPTOR	MWI052826	3/4" CTS X 3/4" NPT STEM ADAPTOR
MWI012826	3/4" CTS X 3/4" NPT STRAIGHT ADAPTOR	MWI502034	1/2" CTS X 1/2" NPSM FEMALE STEM ADAPTOR
MWI052024	1/2" CTS X 1/2" NPT STEM ADAPTOR	WBI2024	1/2" CTS X 1/2" NPT DROP EAR ELBOW



FIGURE 1—JOHN GUEST LOGO