

**ICC-ES PMG Listing****PMG-1058***Effective Date: February 1, 2010\***This listing is subject to re-examination in one year.***www.icc-es.org/pmg | (800) 423-6587 | (562) 699-0543***A Subsidiary of the International Code Council®*

CSI: DIVISION: 15—MECHANICAL  
Section: 15190—Fuel Piping

Product: TracPipe® CounterStrike® Conductive Jacketed Corrugated Stainless Steel Tubing

Listee: OmegaFlex® Inc.  
451 Creamery Way  
Exton, Pennsylvania 19341-2509  
[www.omegaflex.com](http://www.omegaflex.com)

Compliance with the following codes:

2009 *International Fuel Gas Code*® (IFGC)  
2009 *International Mechanical Code*® (IMC)  
2009 *International Residential Code*® (IRC)  
2009 IAPMO *Uniform Plumbing Code*™ (IAPMO UPC™)\*  
2009 IAPMO *Uniform Mechanical Code*™ (IAPMO UMC™)\*

*\*Uniform Mechanical Code and Uniform Plumbing Code are copyrighted publications of the International Association of Plumbing and Mechanical Officials, 5001 East Philadelphia Street, Ontario, California 91761.*

Compliance with the following standards:

ANSI LC 1/CSA 6.26, Fuel Gas Piping Systems Using Corrugated Stainless Steel Tubing (CSST)  
LC1024, PMG Listing Criteria for Conductive Jacketed Corrugated Stainless Steel Tubing  
PMG-1046, OmegaFlex® Inc. TracPipe® Flexible Fuel Gas Piping System

Identification:

Tubing: Each 2 feet (610 mm) of tube bears the trade names TracPipe® CounterStrike®, part number, rated pressure [5 psi (34 kPa)], equivalent hydraulic diameter (EHD), the words “Fuel Gas”, the name of the third-party inspection agency [CSA International (AA-659)] and the ICC-ES PMG listing mark.

Components: Fittings, termination outlets and distribution manifolds are stamped with the OmegaFlex® logo, the part number and a date stamp.

Installation:

General: Installation must be in accordance with the TracPipe® Flexible Gas Piping Guide and Installation Instructions, IFGC Section 404, IRC Section 2415, UMC Section 1309 and IAPMO UPC Section 1211, as applicable. The system installation consists of CSST distribution lines installed between the point of delivery and fuel gas appliances. The use and system installation must be in accordance with ICC-ES PMG-1046.

\*Revised May 5, 2010

*Listings are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the listing or a recommendation for its use. There is no warranty by ICC Evaluation Service, Inc., express or implied, as to any finding or other matter in this listing, or as to any product covered by the listing.*



**Plenum Installation:** When tested in accordance with ASTM E 84, TracPipe® CounterStrike® satisfies the plenum installation requirement, with a flame spread index of less than 25 and a smoke developed index of less than 50.

**Electrical Bonding:** The TracPipe® CounterStrike® Conductive Jacketed Corrugated Stainless Steel Tubing (CSST) System is electrically continuous and is considered to be bonded where it is connected to appliances that are connected to the equipment grounding conductor of the circuit supplying that appliance. Additional bonding prescribed by IFGC Section 310.1.1 is not required for TracPipe® CounterStrike® Conductive Jacketed Corrugated Stainless Steel Tubing when it is installed in accordance with this listing.

**Models:** The TracPipe® CounterStrike® Conductive Jacketed CSST System consists of three parts: (1) a black conductive exterior jacket; (2) corrugated stainless steel tubing which is recognized in PMG-1046 as conforming to ANSI LC-1; and (3) mechanical fittings designed for use only with the OmegaFlex® Inc. CSSTs. Mechanical fittings utilize a metal-to-metal seal, and include mechanical fittings, distribution manifolds, shutoff valves, termination outlet devices, pressure regulators and protection devices.

**Conditions of Listing:**

1. TracPipe® CounterStrike® has been tested (in accordance with LC1024) and shown to resist a transient arc of 1000 amps minimum peak delivering 4.5 coulombs within 20 milliseconds (0.020 seconds). Assumed energy associated with a transient arc from lightning inside a building is less than 2.0 coulombs, providing a factor of safety of 2.25 for CounterStrike. Evaluation of this product for an arc exceeding this level or a direct strike from lightning is outside the scope of this listing.
2. The CSST piping system must not be used as a grounding electrode for an electrical system.
3. Additional information and requirements are defined in ICC-ES PMG-1046.
4. The TracPipe® CounterStrike® is manufactured by OmegaFlex® Inc. in Exton, Pennsylvania, under a quality control program with three surveillance inspections per year by CSA International (AA-659).

**TABLE 1—PART NUMBERS FOR TRACPIPE COUNTERSTRIKE TUBING**

TUBING SIZE (inches)	PART NUMBER
3/8	FGP-CS-375-XXX
1/2	FGP-CS -500-XXX
3/4	FGP-CS -750-XXX
1	FGP-CS -100-XXX
1 1/4	FGP-CS -125-XXX
1 1/2	FGP-CS -150-XXX
2	FGP-CS -200-XXX

For **SI**: 1 inch = 25.4 mm.

XXX: Length of tubing in feet.